

## DRINKING WATER QUALITY AND COMPLIANCE ANNUAL NOTICE TO CONSUMERS

### Introduction

Saskatchewan Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the village of Bladworth's water quality and sample submission compliance record for the January 1, 2008 to December 31, 2008 time period. This report was completed on July 31, 2009. Readers should refer to Environment's *Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202* for more information on minimum sample submission requirements and the meaning of the type of sample. Permit requirements for a specific waterworks may require more sampling that outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

### Water Quality Standards Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	12 12	12 12	0 0

### Water Disinfection – Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	1.27 – 2.3	0.5 – 1.4	12	12	100

### Water Disinfection – Free Chlorine Residual for Water Entering Distribution System from Waterworks Records: From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.2 – 1.2	351	0

### Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.0 NTU	0.43 – 2.3	62	2.3	366	351

### Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on March 3, 2009. Sample results indicated that the provincial drinking water quality standards were not exceeded.

## **General Chemical**

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was submitted on March 3, 2009. Samples exceeded provincial aesthetic objectives for the General Chemical category for the following parameter:

<b>Parameter</b>	<b>Aesthetic Objectives*(mg/L)</b>	<b>Sample Results</b>	<b># Samples Required</b>	<b># Samples Submitted</b>
Sulfate	500	520	1	1

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained from:**

Village of Bladworth  
Box 90  
Bladworth, SK S0G 0J0  
Telephone: 306-567-7744  
Facsimile: 306-567-4299